



February 25, 2021

TO: HOLDERS LIST

SUBJECT: WUT Admin & Marine Building Roof Project
CONTRACT NO. 071399

ADDENDUM NUMBER # 01

This addendum is issued to add the following:

SPECIFICATIONS

A. SECTION 07 53 00 – SINGLE-PLY MEMBRANE ROOFING (PVC)

1.09 ROOF MEMBRANE QUALITY CONTROL

- A. 60-mil minimum thickness roof membrane is required.
- B. Each roll delivered to the site is to be stamped by the manufacturer as "Certified 60-mil Minimum Thickness"; rolls delivered not bearing this certification will be rejected.
- C. The Engineer will field measure the thickness of each roll delivered to the site. Rolls not measuring at 60-mil minimum thickness will be rejected.